

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) #	14301
Facility Name	Amco
Address	59572 Mayfield Rd, Southfield, MI 48034
Operator on Duty Name	James J. Smith
Name of the Person Conducting Inspection	Moham Singh
Date of Inspection	05-30-25
Contact email	
Contact Number	

Operator Training current	☒ Yes ☐ No
Registration/Notification Form	☒ Yes ☐ No
Is Registration current with correct owner, operator etc.	☒ Yes ☐ No

Release Detection Method	☒ ATG ☐ CIM ☐ SIR ☐ IC ☐ Other
Make and Model	U2-TLS350
Does it have paper?	☒ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
Under Dispenser Containments (UDC)	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified	☒ Yes ☐ No
--	---	-------------------	---

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

Signature

Date

www.tanksdata.com

20220516