

APR 26, 2025 2:11 PM
LEAK TEST REPORT
T 1:UNL
PROBE SERIAL NUM 236752
NO TEST DATA AVAILABLE
***** END *****

APR 26, 2025 2:11 PM
CSLD TEST RESULTS - - - -
- - - - -
APR 26, 2025 2:11 PM
T 1:UNL
PROBE SERIAL NUM 236752
0.2 GAL/HR TEST
PER: APR 26, 2025 INCR
T 2:PREM
PROBE SERIAL NUM 236923
0.2 GAL/HR TEST
PER: APR 26, 2025 PASS
T 3:DIESEL
PROBE SERIAL NUM 241675
0.2 GAL/HR TEST
PER: APR 26, 2025 PASS
***** END *****

APR 26, 2025 2:11 PM
LEAK TEST REPORT
T 2:PREM
PROBE SERIAL NUM 236923
NO TEST DATA AVAILABLE
***** END *****

APR 26, 2025 2:11 PM
LIQUID STATUS - - - - -
APR 26, 2025 2:11 PM
L 1:87
SENSOR NORMAL
L 2:UNL INT
SENSOR NORMAL
L 3:SPLIT INT
SENSOR NORMAL
L 4:PREMIUM STP
SENSOR NORMAL
L 5:DIESEL STP
SENSOR NORMAL
***** END *****

APR 26, 2025 2:11 PM
LEAK TEST REPORT
T 3:DIESEL
PROBE SERIAL NUM 241675
NO TEST DATA AVAILABLE
***** END *****