

OCT 25, 2025 5:36 PM

CSLD TEST RESULTS

OCT 25, 2025 5:36 PM

T 1:UNL

PROBE SERIAL NUM 236752

0.2 GAL/HR TEST

PER: OCT 25, 2025 PASS

T 2:PREM

PROBE SERIAL NUM 236923

0.2 GAL/HR TEST

PER: OCT 25, 2025 PASS

T 3:DIESEL

PROBE SERIAL NUM 241675

0.2 GAL/HR TEST

PER: OCT 25, 2025 PASS

* * * * * END * * * * *

OCT 25, 2025 5:36 PM

LIQUID STATUS

OCT 25, 2025 5:36 PM

L 1:87

SENSOR NORMAL

L 2:UNL INT

SENSOR NORMAL

L 3:SPLIT INT

SENSOR NORMAL

L 4:PREMIUM STP

SENSOR NORMAL

L 5:DIESEL STP

SENSOR NORMAL

* * * * * END * * * * *