

JUL 29, 2025 7:27 PM

CSLD TEST RESULTS

JUL 29, 2025 7:27 PM

T 1:UNL
PROBE SERIAL NUM 236752

0.2 GAL/HR TEST
PER: JUL 29, 2025 PASS

T 2:PREM
PROBE SERIAL NUM 236923

0.2 GAL/HR TEST
PER: JUL 29, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 241675

0.2 GAL/HR TEST
PER: JUL 29, 2025 PASS

* * * * * END * * * * *

JUL 29, 2025 7:27 PM

LIQUID STATUS

JUL 29, 2025 7:27 PM

L 1:87
SENSOR NORMAL

L 2:UNL INT
SENSOR NORMAL

L 3:SPLIT INT
SENSOR NORMAL

L 4:PREMIUM STP
SENSOR NORMAL

L 5:DIESEL STP
SENSOR NORMAL

* * * * * END * * * * *