

JAN 24, 2025 8:00 AM

CSLD TEST RESULTS

- - - - -

JAN 24, 2025 8:00 AM

T 1:UNL

PROBE SERIAL NUM 236752

0.2 GAL/HR TEST

PER: JAN 24, 2025 PASS

T 2:PREM

PROBE SERIAL NUM 236923

0.2 GAL/HR TEST

PER: JAN 24, 2025 FAIL

T 3:DIESEL

PROBE SERIAL NUM 241675

0.2 GAL/HR TEST

PER: JAN 24, 2025 PASS

JAN 24, 2025 1:17 PM

LIQUID STATUS

- - - - -

JAN 24, 2025 1:17 PM

L 1:87

SENSOR NORMAL

L 2:UNL INT

SENSOR NORMAL

L 3:SPLIT INT

FUEL ALARM

L 4:PREMIUM STP

SENSOR NORMAL

L 5:DIESEL STP

FUEL ALARM

* * * * * END * * * * *

JAN 24, 2025 1:17 PM

LEAK TEST REPORT

T 1:UNL

PROBE SERIAL NUM 236752

NO TEST DATA AVAILABLE

* * * * * END * * * * *

JAN 24, 2025 1:17 PM

LEAK TEST REPORT

T 2:PREM

PROBE SERIAL NUM 236923

NO TEST DATA AVAILABLE

* * * * * END * * * * *

JAN 24, 2025 1:17 PM

LEAK TEST REPORT

T 3:DIESEL

PROBE SERIAL NUM 241675

NO TEST DATA AVAILABLE

- - - - - END - - - - -