

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELPHART IN 46514
574.327.6685

JAN 31. 2023 12:54

CSLD TEST RESULTS

JAN 31. 2023 12:54

T 1:REG UNLEADED 1
PROBE SERIAL NUM 239755
0.2 GAL/HR TEST
PER: JAN 31. 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 249209
0.2 GAL/HR TEST
PER: JAN 31. 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 477590
0.2 GAL/HR TEST
PER: JAN 31. 2023 PASS

T 4:KEROSENE
PROBE SERIAL NUM 248802
0.2 GAL/HR TEST
PER: JAN 31. 2023 PASS

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELPHART IN 46514
574.327.6685

JAN 31. 2023 12:54

LEAK TEST REPORT

T 1:REG UNLEADED 1
PROBE SERIAL NUM 239755

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELPHART IN 46514
574.327.6685

JAN 31. 2023 12:54

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 249209

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELPHART IN 46514
574.327.6685

JAN 31. 2023 12:54

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 477590

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELPHART IN 46514
574.327.6685

JAN 31. 2023 12:54

LEAK TEST REPORT

T 4:KEROSENE
PROBE SERIAL NUM 248802

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELPHART IN 46514
574.327.6685

JAN 31. 2023 12:54

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REG UNLEADED 1

3.0 GAL/HR RESULTS: