

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

SEP 5. 2023 12:14

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REG UNLEADED 1

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 5. 2023 12:13 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 96
SINCE MIDNIGHT : 42

0.20 GAL/HR RESULTS:

JUN 1. 2015 22:16 PASS
MAY 24. 2015 22:54 PASS
MAY 20. 2015 7:04 PASS
MAY 12. 2015 23:16 PASS
MAY 5. 2015 6:13 PASS
APR 28. 2015 23:16 PASS
APR 22. 2015 21:58 PASS
APR 16. 2015 22:34 PASS
APR 10. 2015 23:19 PASS
APR 8. 2015 21:54 PASS

0.10 GAL/HR RESULTS:

APR 11. 2015 1:10 PASS
OCT 6. 2014 23:44 PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 5. 2023 12:10 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 11
SINCE MIDNIGHT : 4

0.20 GAL/HR RESULTS:

JUN 30. 2015 3:14 PASS
MAY 26. 2015 23:12 PASS
MAY 20. 2015 12:35 PASS
MAY 14. 2015 23:34 PASS
MAY 8. 2015 23:20 PASS
MAY 2. 2015 9:07 PASS
APR 24. 2015 22:18 PASS
APR 16. 2015 21:34 PASS
APR 10. 2015 22:52 PASS
APR 8. 2015 22:23 PASS