

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D.( FID) #	264	Contact Number	
Facility Name	Phillips 66	Contact email	
Address	1606 Cassopolis Elkhart 46514	Date of Inspection	5/5/23
Operator on Duty Name		Name of the Person Conducting Inspection	Josh Rider
<b>Operator Training</b>			
Operator Training current	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
<b>Registration/Notification Form</b>			
Is Registration current with correct owner, operator etc.	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
<b>Release Detection</b>			
Release Detection Method	<input checked="" type="radio"/> ATG <input type="radio"/> FIM <input type="radio"/> SIR <input type="radio"/> IC <input type="radio"/> Other		
Make and Model	VR TLS-350		
Does it have paper?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Is it in Alarm mode?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Interstitial Monitoring Sensor Status Normal	<input type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
Necessary Monthly Printout Taken	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
<b>Spill Buckets</b>			
Are Spill Buckets Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
Are the Spill Bucket in good condition and free of damage/cracks	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
<b>Fill Ports</b>			
Is Fill pipe cap tight and fill pipe free from any obstruction?	<input checked="" type="radio"/> Yes <input type="radio"/> No	Operator Notified	<input type="radio"/> Yes <input type="radio"/> No
<b>Piping/STP Sumps</b>			
Are Sumps Clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
<b>Under Dispenser Containments (UDC)</b>			
Are UDCs clean and free from water, debris, product etc?	<input type="radio"/> Yes <input checked="" type="radio"/> No	Operator Notified	<input checked="" type="radio"/> Yes <input type="radio"/> No
<i>NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.</i>			
Operator on Duty Name	317-645-0215	Signature	Date
	tanksdata@gmail.com		www.tanksdata.com

CASSOPOLIS QUIK PART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

MAY 5, 2023 12:14

COLD TEST RESULTS

MAY 5, 2023 12:14

T 1:REG UNLEADED 1  
PROBE SERIAL NUM 239755

0.2 GAL/HR TEST  
PER: MAY 5, 2023 PASS

T 2:PREMIUM  
PROBE SERIAL NUM 249209

0.2 GAL/HR TEST  
PER: MAY 5, 2023 PASS

T 3:DIESEL  
PROBE SERIAL NUM 477590

0.2 GAL/HR TEST  
PER: MAY 5, 2023 PASS

T 4:FERROSENE  
PROBE SERIAL NUM 248802

0.2 GAL/HR TEST  
PER: NO RESULTS AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK PART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

MAY 5, 2023 12:14

LEAK TEST REPORT

T 1:REG UNLEADED 1  
PROBE SERIAL NUM 239755

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK PART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

MAY 5, 2023 12:14

LEAK TEST REPORT

T 2:PREMIUM  
PROBE SERIAL NUM 249209

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK PART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

MAY 5, 2023 12:14

LEAK TEST REPORT

T 3:DIESEL  
PROBE SERIAL NUM 477590

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK PART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

MAY 5, 2023 12:14

LEAK TEST REPORT

T 4:FERROSENE  
PROBE SERIAL NUM 248802

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK PART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

MAY 5, 2023 12:14

PRESSURE LINE LEAK  
TEST RESULTS

Q 1:REG UNLEADED 1

3.0 GAL/HR RESULTS: