

CASSOPOLIS QUIK MART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

JUL 19, 2023 12:53

COLD TEST RESULTS

JUL 19, 2023 12:53

T 1:REG UNLEADED 1  
PROBE SERIAL NUM 239755

0.2 GAL/HR TEST

PER: JUL 19, 2023 PASS

T 2:PREMIUM  
PROBE SERIAL NUM 249209

0.2 GAL/HR TEST

PER: JUL 19, 2023 PASS

T 3:DIESEL  
PROBE SERIAL NUM 477590

0.2 GAL/HR TEST

PER: JUL 19, 2023 PASS

T 4:KEROSENE  
PROBE SERIAL NUM 248802

0.2 GAL/HR TEST

PER:NO RESULTS AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK MART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

JUL 19, 2023 12:53

LEAK TEST REPORT

T 1:REG UNLEADED 1  
PROBE SERIAL NUM 239755

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK MART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

JUL 19, 2023 12:53

LEAK TEST REPORT

T 2:PREMIUM  
PROBE SERIAL NUM 249209

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK MART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

JUL 19, 2023 12:53

LEAK TEST REPORT

T 3:DIESEL  
PROBE SERIAL NUM 477590

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK MART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

JUL 19, 2023 12:53

LEAK TEST REPORT

T 4:KEROSENE  
PROBE SERIAL NUM 248802

NO TEST DATA AVAILABLE

\*\*\*\*\* END \*\*\*\*\*

CASSOPOLIS QUIK MART  
1606CASSOPOLIS ST  
ELKHART IN 46514  
574.327.6685

JUL 19, 2023 12:53

PRESSURE LINE LEAK  
TEST RESULTS

G 1:REG UNLEADED 1

3.0 GAL/HR RESULTS: