

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685
DEC 4, 2023 12:38
CSLD TEST RESULTS
DEC 4, 2023 12:38

T 1:REG UNLEADED 1
PROBE SERIAL NUM 239755
0.2 GAL/HR TEST
PER: DEC 4, 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 249209
0.2 GAL/HR TEST
PER: DEC 4, 2023 PASS

T 3:DIESEL
PROBE SERIAL NUM 477590
0.2 GAL/HR TEST
PER: DEC 4, 2023 PASS

T 4:KEROSENE
PROBE SERIAL NUM 248802
0.2 GAL/HR TEST
PER: DEC 4, 2023 PASS

***** END *****

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

DEC 4, 2023 12:39
LEAK TEST REPORT
T 1:REG UNLEADED 1
PROBE SERIAL NUM 239755

NO TEST DATA AVAILABLE
***** END *****

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

DEC 4, 2023 12:39
LEAK TEST REPORT
T 2:PREMIUM
PROBE SERIAL NUM 249209

NO TEST DATA AVAILABLE
***** END *****

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

DEC 4, 2023 12:39
LEAK TEST REPORT
T 3:DIESEL
PROBE SERIAL NUM 477590

NO TEST DATA AVAILABLE
***** END *****

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

DEC 4, 2023 12:39
LEAK TEST REPORT
T 4:KEROSENE
PROBE SERIAL NUM 248802

NO TEST DATA AVAILABLE
***** END *****

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

DEC 4, 2023 12:39
PRESSURE LINE LEAK
TEST RESULTS

G 1:REG UNLEADED 1
3.0 GAL/HR RESULTS: