



5296 Breakers Way, Carmel, IN 46033

Date

PRODUCT LINE TEST

Test Location Information

Name	FID 264
Address	1606 Cassopolis St
City	Elkhart, IN 46514
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:20p	90	0	0.0037	0	0
12:35p	90	0	0.0037	0	0
12:50p	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:00pm	84	0	0.0037	0	0
1:15pm	84	0	0.0037	0	0
1:30pm	84	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
1:45pm	90	0	0.0037	0	0
2:00pm	89	-1	0.0037	.0037	.0148
2:15pm	89	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type : Kerosene

TIME	DATA	+/-	GPL	RES	GPH
2:35pm	89	0	0.0037	0	0
2:50pm	89	0	0.0037	0	0
3:05pm	89	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					



5296 Breakers Way, Carmel, IN 46033

Date 10/9/24

PRODUCT LINE TEST

Test Location Information

Name	FID 264
Address	1606 Cassopolis St
City	Elkhart, IN 46514
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4	Kerosene	Pass
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 