



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

10/9/24

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 264
Address	1606 Cassopolis St
City	Elkhart, IN 46514
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket ELLD		
Prem	Red Jacket ELLD		
Dies	Red Jacket ELLD		
Kero	Red Jacket ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular				189ml	1 cycle	Pass 
2	Premium				189ml	1 cycle	Pass 
3	Diesel				189ml	1 cycle	Pass 
4	Kerosene				189ml	1 cycle	Pass 
5					189ml		. 
6					189ml		. 
7					189ml		. 
8					189ml		. 

Comment:

Technician Signature :

