

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685
JAN 29, 2024 12:19
COLD TEST RESULTS
- - - - -
JAN 29, 2024 12:19

T 1:REG UNLEADED 1
PROBE SERIAL NUM 239755
0.2 GAL/HR TEST
PER: JAN 29, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 249209
0.2 GAL/HR TEST
PER: JAN 28, 2024 PASS

T 3:DIESEL
PROBE SERIAL NUM 477590
0.2 GAL/HR TEST
PER: JAN 29, 2024 PASS

T 4:KEROSENE
PROBE SERIAL NUM 248802
0.2 GAL/HR TEST
PER: JAN 29, 2024 PASS

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

JAN 29, 2024 12:19

LEAK TEST REPORT
T 1:REG UNLEADED 1
PROBE SERIAL NUM 239755

NO TEST DATA AVAILABLE
* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

JAN 29, 2024 12:19

LEAK TEST REPORT
T 2:PREMIUM
PROBE SERIAL NUM 249209

NO TEST DATA AVAILABLE
* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

JAN 29, 2024 12:19

LEAK TEST REPORT
T 3:DIESEL
PROBE SERIAL NUM 477590

NO TEST DATA AVAILABLE
* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

JAN 29, 2024 12:19

LEAK TEST REPORT
T 4:KEROSENE
PROBE SERIAL NUM 248802

NO TEST DATA AVAILABLE
* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

JAN 29, 2024 12:19

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REG UNLEADED 1

0.2 GAL/HR RESULTS