

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

MAY 25, 2025 17:09

LEAK TEST REPORT

T 1:REG UNLEADED 1
PROBE SERIAL NUM 248802

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

MAY 25, 2025 17:09

CSLD TEST RESULTS

MAY 25, 2025 17:09

T 1:REG UNLEADED 1
PROBE SERIAL NUM 248802

0.2 GAL/HR TEST
PER: MAY 25, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 249209

0.2 GAL/HR TEST
PER: MAY 25, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 477590

0.2 GAL/HR TEST
PER: MAY 25, 2025 PASS

T 4:KEROSENE
PROBE SERIAL NUM 239755

0.2 GAL/HR TEST
PER:NO RESULTS AVAILABLE

* * * * * END * * * * *

CASSOPOLIS QUIK MART
606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

MAY 25, 2025 17:09

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 249209

NO TEST DATA AVAILABLE

* * * * * END * * * * *

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

MAY 25, 2025 17:09

LEAK TEST REPORT

T 3:DIESEL
PROBE SERIAL NUM 477590

NO TEST DATA AVAILABLE

***** END *****

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

MAY 25, 2025 17:09

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REG UNLEADED 1

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 25, 2025 17:01 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 76
SINCE MIDNIGHT : 58

0.20 GAL/HR RESULTS:

JUN 1, 2015	22:16	PASS
MAY 24, 2015	22:54	PASS
MAY 20, 2015	7:04	PASS
MAY 12, 2015	20:16	PASS
MAY 5, 2015	6:10	PASS
APR 28, 2015	23:16	PASS
APR 22, 2015	21:58	PASS
APR 16, 2015	23:04	PASS
APR 10, 2015	23:19	PASS
APR 8, 2015	21:54	PASS

0.10 GAL/HR RESULTS:

APR 11, 2015 1:10 PASS
OCT 6, 2014 23:44 PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 25, 2025 14:45 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 5
SINCE MIDNIGHT : 3

0.20 GAL/HR RESULTS:

JUN 30, 2015	3:14	PASS
MAY 26, 2015	23:12	PASS
MAY 20, 2015	12:35	PASS
MAY 14, 2015	23:35	PASS
MAY 8, 2015	23:34	PASS
MAY 2, 2015	23:20	PASS
APR 24, 2015	9:07	PASS
APR 16, 2015	22:18	PASS
APR 10, 2015	21:34	PASS
APR 8, 2015	22:52	PASS
APR 8, 2015	22:23	PASS

0.10 GAL/HR RESULTS:

APR 10, 2015 23:47 PASS
OCT 6, 2014 23:49 PASS

Q 3:DIESEL

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 25, 2025 16:28 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 2
SINCE MIDNIGHT : 2

0.20 GAL/HR RESULTS:

MAY 26, 2015	15:58	PASS
MAY 20, 2015	20:19	PASS
MAY 16, 2015	11:13	PASS
MAY 10, 2015	12:37	PASS
MAY 4, 2015	21:31	PASS
APR 30, 2015	10:47	PASS
APR 24, 2015	17:58	PASS
APR 20, 2015	9:04	PASS
APR 14, 2015	15:12	PASS
APR 12, 2015	14:56	PASS

0.10 GAL/HR RESULTS:

APR 14, 2015 16:24 PASS
OCT 12, 2014 10:33 PASS

Q 4:KEROSENE

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 24, 2025 9:43 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 0
SINCE MIDNIGHT : 0

0.20 GAL/HR RESULTS:

SEP 11, 2015	10:50	PASS
AUG 12, 2015	17:47	PASS
MAY 20, 2015	11:29	PASS
MAY 5, 2015	6:35	PASS
APR 18, 2015	13:32	PASS
APR 8, 2015	11:33	PASS
APR 1, 2015	6:53	PASS
MAR 31, 2015	11:14	PASS
MAR 25, 2015	13:14	PASS
MAR 19, 2015	19:01	PASS

0.10 GAL/HR RESULTS:

APR 8, 2015 14:41 PASS
OCT 6, 2014 12:55 PASS

CASSOPOLIS QUIK MART
1606CASSOPOLIS ST
ELKHART IN 46514
574.327.6685

MAY 25, 2025 17:09

LEAK TEST REPORT

T 4:KEROSENE
PROBE SERIAL NUM 239755

NO TEST DATA AVAILABLE

***** END *****