



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 264
Address	1606 Cassopolis St
City	Elkhart, IN, 46514
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Red Jacket ELLD		
Prem	Red Jacket ELLD		
Dies	Red Jacket ELLD		
Kero	Red Jacket ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	30	22	80 ml	189ml	2 cycles	Pass v
2	Premium	33	22	110 ml	189ml	2 cycles	Pass v
3	Diesel	33	23	130 ml	189ml	2 cycles	Pass v
4	Kerosene	32	24	130 ml	189ml	2 cycles	Pass v
5					189ml		. v
6					189ml		. v
7					189ml		. v
8					189ml		. v

Comment:

Technician Signature :

