

TRIENNIAL INSPECTION

Facility Name: QUICK MART

Test Date: 05/29/2025

Facility Address: 1606 CASSOPOLIS STREET ELKHART IN ...

Facility ID: 264

SPILL CONTAINER INTEGRITY TESTING

Product	Pul							
Test Type	Initial							
Clean of liquid/debris	YES							
VISUAL INSPECTION	PASS							
Test Start Time	9:00							
Test End Time	10:00							
Starting Water Level (inches)	13							
Ending Water Level (inches)	13							
Water Level Change (inches)	0							
HYDROSTATIC TEST RESULT	PASS							
Double wall	NO							
Vacuum Test Length (minutes)								
Starting Inches of Water								
Ending Inches of Water								
VACUUM TEST RESULT								

Comments

Technician Name: Andrew Bakker

Dispatch # 7650

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19