

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
05/19/2023 14:53:01

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
05/19/2023 14:53:01

PREM STP
Alarm
05/19/2023 14:53:01

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
05/19/2023 14:53:41

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin End
05/19/2023 05/19/2023
04:48:17 08:02:34
Result Pass
Slope -0.01
Status 0
Volume Qualify(%) 14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin End
05/06/2023 05/06/2023
05:28:52 06:55:44
Result Pass
Slope -0.07
Status 0
Volume Qualify(%) 14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
05/19/2023 14:54:22

TANK TEST REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity 6,016.0

Begin End
07/22/2020 07/22/2020
00:00:55 00:01:04
-----Gross-----
1,696.9 1,696.9
-----Water Level-----
0.02 0.02
-----Water Volume-----
0.0 0.0
-----Net-----
1,686.3 1,686.3
-----Level-----
31.17 31.17
-----Temperature-----
70.07 70.07

Last Delivery
07/18/2020 13:06:30
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 28.21

UNLEAD 3
UNLEADED
Capacity 4,011.0

Begin End
07/22/2020 07/22/2020
00:00:57 03:09:41
-----Gross-----
950.9 955.8
-----Water Level-----
0.03 0.03
-----Water Volume-----
0.1 0.1
-----Net-----