

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
06/20/2023 15:13:01

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
06/20/2023 15:13:01

PREM STP
Alarm
06/20/2023 15:13:01

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
06/20/2023 15:13:46

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0
Begin End
06/20/2023 06/20/2023
01:40:13 03:06:30
Result Pass
Slope 0.05
Status 0
Volume Qualify(%) 14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0
Begin End
05/23/2023 05/23/2023
01:30:45 02:58:31
Result Pass
Slope 0.04
Status 0
Volume Qualify(%) 14

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
06/20/2023 15:14:32

TANK TEST REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity 6,016.0
Begin End
07/22/2020 07/22/2020
00:00:55 00:01:04
-----Gross-----
1,696.9 1,696.9
-----Water Level-----
0.02 0.02
-----Water Volume-----
0.0 0.0
-----Net-----
1,606.3 1,606.3
-----Level-----
31.17 31.17
-----Temperature-----
70.07 70.07

Last Delivery
07/18/2020 13:06:30
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 28.21

UNLEAD 3
UNLEADED
Capacity 4,011.0

Begin End
07/22/2020 07/22/2020
00:00:57 03:09:41
-----Gross-----
950.9 955.8
-----Water Level-----