

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
02/15/2023 17:22:06

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin End
02/15/2023 02/15/2023
05:29:02 07:21:23
Result Pass
Slope -0.06
Status 0
Volume Qualify(%) 14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin End
01/07/2023 01/07/2023
03:44:59 06:10:03
Result Pass
Slope 0.00
Status 0
Volume Qualify(%) 14

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
02/15/2023 17:22:41

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
02/15/2023 17:22:41

PREM STP
Alarm
02/15/2023 17:22:41

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
02/15/2023 17:22:57

TANK TEST REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity 6,016.0

Begin End
07/22/2020 07/22/2020
00:00:55 00:01:04
-----Gross-----
1,696.9 1,696.9
-----Water Level-----
0.02 0.02
-----Water Volume-----
0.0 0.0
-----Net-----
1,606.3 1,606.3
-----Level-----
31.17 31.17
-----Temperature-----
70.07 70.07

Last Delivery
07/18/2020 13:06:30
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 28.21

UNLEAD 3
UNLEADED
Capacity 4,011.0

Begin End
07/22/2020 07/22/2020
00:00:57 03:09:41
-----Gross-----
958.9 955.0