

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
09/08/2023 14:58:46
SENSOR REPORT
Last Available
2 WIRE SENSOR
UNL STP
Alarm
09/08/2023 14:58:46
PREM STP
Alarm
09/08/2023 14:58:46
3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
09/08/2023 14:59:21
SCALO REPORT
Last Available
units:gal, in, °F
TANKS
PREMIUM
PREM
Capacity: 6,016.0
Begin End
09/08/2023 09/08/2023
03:51:11 05:54:57
Result Pass
Slope 0.02
Status 0
Volume Qualify(%) 14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0
Begin End
08/09/2023 08/09/2023
01:41:40 03:08:32
Result Pass
Slope -0.06
Status 0
Volume Qualify(%) 14

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
09/08/2023 14:59:47
TANK TEST REPORT
Last Available
units:gal, in, °F
TANKS
PREMIUM
PREM
Capacity 6,016.0
Begin End
07/22/2020 07/22/2020
00:00:55 00:01:04
-----Gross-----
1,696.9 1,696.9
-----Water Level-----
0.02 0.02
-----Water Volume-----
0.0 0.0
-----Net-----
1,686.3 1,686.3
-----Level-----
31.17 31.17
-----Temperature-----
70.07 70.07

Last Delivery
07/18/2020 13:06:30
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 28.21
UNLEAD 3
UNLEADED
Capacity 4,011.0
Begin End
07/22/2020 07/22/2020
00:00:57 03:09:41
-----Gross-----
958.9 955.0