

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

12/22/2024 16:47:08

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM

REM
Capacity: 6,016.0

Begin	End
12/22/2024 13:28:02	12/22/2024 16:30:55
Result	Pass
Slope	0.04
Status	0
Volume Qualify(%)	14

MANIFOLDS

Manifold 1

UNLEADED
Capacity: 12,033.0

Begin	End
11/10/2024 03:16:07	11/10/2024 04:43:49
Result	Pass
Slope	0.06
Status	0
Volume Qualify(%)	14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

12/22/2024 16:47:09

REGULATORY REPORT
(Passed Tests)
December 2024

units:gph

TANKS (MONTHLY)

Tank 1

PREMIUM

SCALD
Slope 0.04

▶ 12/22/2024 13:28:02

⊗ 12/22/2024 16:30:55

Slope -0.01

▶ 12/05/2024 10:26:41

⊗ 12/05/2024 13:49:46

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

12/22/2024 16:47:09

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP

Alarm
12/22/2024 16:47:09

PREM STP

Alarm
12/22/2024 16:47:09

3 WIRE SENSOR

No Records Found

MAG SENSOR