

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
10/03/2024 15:23:56

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin	End
10/03/2024 10:41:45	10/03/2024 14:46:59
Result	Pass
Slope	-0.03
Status	0
Volume Qualify(%)	14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin	End
10/02/2024 03:23:52	10/02/2024 05:17:31
Result	Pass
Slope	-0.02
Status	0
Volume Qualify(%)	14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
10/03/2024 15:24:01

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
10/03/2024 15:24:01

PREM STP
Alarm
10/03/2024 15:24:01

3 WIRE SENSOR

No Records Found

-----MAG SENSOR-----

No Records Found

COLFAX EXPRESS

MARATHON

831 E COLFAX

SOUTH BEND

574-232-6727

USA

10/03/2024 15:24:02

REGULATORY REPORT

(Passed Tests)

October 2024

units:gph

TANKS (MONTHLY)

Tank 1

PREMIUM

SCALD

Slope -0.03

▶ 10/03/2024 10:41:45

⊗ 10/03/2024 14:46:59

MANIFOLDS (SCALD MONTHLY)

Manifold 1

Manifold 1

Slope -0.0162

▶ 10/02/2024 03:23:52

⊗ 10/02/2024 05:17:31

BBEN

BBENJON

JUNK

0012:0012 10/02/24

1921 0631J0010

20000 066001

10/03/2024 12:53:20

020

234-525-0133

SOUTH BEND

831 E COLFAX