

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
08/05/2024 15:44:45

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin	End
08/05/2024 02:48:57	08/05/2024 04:15:44
Result	Pass
Slope	0.07
Status	0
Volume Qualify(%)	14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin	End
07/20/2024 03:25:03	07/20/2024 04:53:17
Result	Pass
Slope	-0.03
Status	0
Volume Qualify(%)	14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
08/05/2024 15:44:51

REGULATORY REPORT
(Passed Tests)
August 2024

units:gph

TANKS (MONTHLY)

Tank 1
PREMIUM
SCALD
Slope 0.07
• 08/05/2024 02:48:57
• 08/05/2024 04:15:44

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
08/05/2024 15:44:57

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
08/05/2024 15:44:57

PREM STP
Alarm
08/05/2024 15:44:57

3 WIRE SENSOR

No Records Found

MAG SENSOR

Probe 101
Sensor Missing Alarm
08/05/2024 15:44:57

.....