

30 DAYS WALK THROUGH INSPECTION

001
Tanks Data

UST Facility I.D. (FID) # 15294

Facility Name MARATHON

Address 831 E Colfax Ave, South Bend

Operator on Duty Name In 4/6/17

Contact Number

Contact email

Date of Inspection 07/07/24

Name of the Person Conducting Inspection AKSHIT SHAHAN

Operator Training current

Operator Training
☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection
☒ MTG ☐ CIM ☐ SIR ☐ TC ☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Spill Buckets

☐ Yes ☒ No Operator Notified ☐ Yes ☒ No

Are Spill Buckets Clean and free from water, debris, product etc?
 Are the Spill Bucket in good condition and free of damage/cracks

☐ Yes ☒ No Operator Notified ☐ Yes ☒ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports
☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

Pipeline/STP Sumps
☐ Yes ☒ No Operator Notified ☐ Yes ☒ No

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)
☐ Yes ☒ No Operator Notified ☐ Yes ☒ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com