

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
11/08/2024 15:07:11

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin	End
11/05/2024 11/05/2024	11/05/2024 11/05/2024
13:11:41	15:14:48
Result	Pass
Slope	-0.04
Status	0
Volume Qualify(%)	14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin	End
11/06/2024 11/06/2024	11/06/2024 11/06/2024
04:04:46	05:31:08
Result	Pass
Slope	-0.06
Status	0
Volume Qualify(%)	14

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
11/08/2024 15:07:17

REGULATORY REPORT
(Passed Tests)
November 2024

units:gph

TANKS (MONTHLY)

Tank 1
PREMIUM
SCALD
Slope -0.04
▶ 11/05/2024 13:11:41
⊙ 11/05/2024 15:14:48

MANIFOLDS(SCALD MONTHLY)

Manifold 1
Manifold 1
Slope -0.0608
▶ 11/06/2024 04:04:46
⊙ 11/06/2024 05:31:08

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
11/08/2024 15:07:17

SENSOR REPORT
Last Available

2 WIRE SENSOR

UHL STP
Alarm
11/08/2024 15:07:17

PREM STP
Alarm
11/08/2024 15:07:17

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found