

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
01/22/2024 12:33:37

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
01/22/2024 12:33:37

PREM STP
Alarm
01/22/2024 12:33:37

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
01/22/2024 12:34:08

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin	End
01/22/2024 03:56:25	01/22/2024 05:24:20
Result	Pass
Slope	-0.00
Status	0
Volume Qualify(%)	14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin	End
12/26/2023 04:25:06	12/26/2023 05:52:43
Result	Pass
Slope	0.01
Status	0
Volume Qualify(%)	14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
01/22/2024 12:34:28

TANK TEST REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity 6,016.0

Begin	End
07/22/2020 00:00:55	07/22/2020 00:01:04
-----Gross-----	
1.696.9	1.696.9
-----Water Level-----	
0.02	0.02
-----Water Volume-----	
0.0	0.0
-----Net-----	
1.686.3	1.686.3
-----Level-----	
31.17	31.17
-----Temperature-----	
70.07	70.07

Last Delivery
07/10/2020 13:06:30
Test Type Monthly(0.2)
Threshold 0.10
Leak Rate 0.00
Result Aborted
Capacity(%) 20.21

UNLEAD 3
UNLEADED
Capacity 4,011.0

Begin	End
07/22/2020 00:00:57	07/22/2020 03:09:41
-----Gross-----	
950.9	955.8
-----Water Level-----	
0.03	0.03
-----Water Volume-----	
0.1	0.1
-----Net-----	
949.1	946.2
-----Level-----	
10.46	10.42