

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
09/02/2024 16:36:20

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0
Begin End
08/30/2024 08/30/2024
04:12:33 05:39:20
Result Pass
Slope 0.03
Status 0
Volume Qualify(%) 14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0
Begin End
08/11/2024 08/11/2024
05:42:32 07:09:19
Result Pass
Slope -0.03
Status 0
Volume Qualify(%) 14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
09/02/2024 16:36:26

REGULATORY REPORT
(Passed Tests)
September 2024

units:gph

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
09/02/2024 16:36:27

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
09/02/2024 16:36:27

PREM STP
Alarm
09/02/2024 16:36:27

3 WIRE SENSOR

No Records Found

MAG SENSOR

Probe 101
Sensor Missing Alarm
09/02/2024 16:36:27

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

09/02/2024 16:37:02

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Alarm
09/02/2024 16:37:02

PREM STP
Alarm
09/02/2024 16:37:02

3 WIRE SENSOR

No Records Found

MAG SENSOR

Probe 101
Sensor Missing Alarm
09/02/2024 16:37:02

.....

.....

nojwne 009711000 11
2f9402 0
0jobs 0:03
0sanff 6422
02:45:35 01:00:10
08\TT\3034 08\TT\3034
06d1u 209

03000000 15:02:00

00000000

00000000

00000000