

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
04/17/2025 16:34:42
TANK TEST REPORT
Last Available

units: gal, in, °F

TANKS

PREMIUM

PREM

Capacity 6,016.0

Begin	End
07/22/2020 00:00:55	07/22/2020 00:01:04
-----Gross-----	
1,696.9	1,696.9
-----Water Level-----	
0.02	0.02
-----Water Volume-----	
0.0	0.0
-----Net-----	
1,686.3	1,686.3
-----Level-----	
31.17	31.17
-----Temperature-----	
70.07	70.07

Last Delivery

07/18/2020 13:06:30	Monthly(0.2)
Test Type	
Threshold	0.10
Leak Rate	0.00
Result	Aborted
Capacity(%)	28.21

UNLEAD 3

UNLEADED

Capacity 4,011.0

Begin	End
07/22/2020 00:00:57	07/22/2020 03:09:41
-----Gross-----	
958.9	955.8
-----Water Level-----	
0.03	0.03
-----Water Volume-----	
0.1	0.1
-----Net-----	
949.1	946.2
-----Level-----	
18.46	18.42
-----Temperature-----	
74.59	74.35

Last Delivery

07/02/2020 10:49:30	Monthly(0.2)
Test Type	
Threshold	0.10
Leak Rate	-0.11
Result	Fail
Capacity(%)	23.83

Details

07/22/2020 03:01:08	
Net	946.2
Temperature	74.36
Level	18.42
07/22/2020 02:01:08	
Net	946.2
Temperature	74.42
Level	18.42
07/22/2020 01:01:07	
Net	946.2
Temperature	74.50
Level	18.42

UNLEAD 1

UNLEADED

Capacity 4,011.0

Begin	End
07/22/2020 00:01:00	07/22/2020 02:59:31
-----Gross-----	
688.8	676.9
-----Water Level-----	
0.03	0.03
-----Water Volume-----	
0.1	0.1
-----Net-----	
681.0	669.4
-----Level-----	
14.65	14.48
-----Temperature-----	
75.93	75.74

Last Delivery

07/02/2020 10:49:30	Monthly(0.2)
Test Type	
Threshold	0.10
Leak Rate	-0.77
Result	Fail
Capacity(%)	16.88

Details

07/22/2020 02:01:01	
Net	669.4
Temperature	75.80
Level	14.48
07/22/2020 01:01:00	
Net	669.4
Temperature	75.89
Level	14.48

UNLEAD2

UNLEADED

Capacity 4,011.0

Begin	End
07/22/2020 00:00:53	07/22/2020 02:49:21
-----Gross-----	
555.4	554.6
-----Water Level-----	
0.03	0.03
-----Water Volume-----	
0.1	0.1
-----Net-----	
549.3	548.6
-----Level-----	
12.64	12.63
-----Temperature-----	
75.62	75.46

Last Delivery

07/02/2020 10:49:30	Monthly(0.2)
Test Type	
Threshold	0.10
Leak Rate	-0.01
Result	Pass
Capacity(%)	13.83

Details

07/22/2020 02:01:03	
Net	548.6
Temperature	75.50
Level	12.63
07/22/2020 01:01:02	
Net	548.6
Temperature	75.57
Level	12.63

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

04/17/2025 16:34:44

REGULATORY REPORT
(Passed Tests)
April 2025

units:gph

TANKS (MONTHLY)

Tank 1
PREMIUM
SCALD 0.00
Slope
▶ 04/17/2025 04:33:21
⊗ 04/17/2025 06:36:37
Slope -0.08
▶ 04/02/2025 19:27:47
⊗ 04/02/2025 20:55:28

2 WIRE SENSOR (MONTHLY)

UNL STP
04/17/2025 12:00:00
04/01/2025 12:00:00

PREM STP
04/17/2025 12:00:00
04/08/2025 12:00:00

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

04/17/2025 16:34:45

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin End
04/17/2025 04/17/2025
04:33:21 06:36:37
Result Pass
Slope 0.00
Status 0
Volume Qualify(%) 14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin End
03/20/2025 03/20/2025
11:11:10 12:38:51
Result Pass
Slope 0.03
Status 0
Volume Qualify(%) 14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

04/17/2025 16:34:50

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
OK
04/17/2025 16:34:50

PREM STP
OK
04/17/2025 16:34:50

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found