

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

07/10/2025 14:53:02

REGULATORY REPORT
(Passed Tests)
July 2025

units:gph

TANKS (MONTHLY)

Tank 1
PREMIUM
SCALD
Slope 0.02
▶ 07/10/2025 09:32:44
⊙ 07/10/2025 11:42:06
Slope -0.05
▶ 07/01/2025 03:52:54
⊙ 07/01/2025 05:20:34

MANIFOLDS (SCALD MONTHLY)

Manifold 1
Manifold 1
Slope -0.0170
▶ 07/10/2025 03:26:26
⊙ 07/10/2025 04:53:49

2 WIRE SENSOR (MONTHLY)

UNL STP
07/10/2025 12:00:00
.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

07/10/2025 14:53:07

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Ok
07/10/2025 14:53:07

PREM STP
Alarm
07/10/2025 14:53:07

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

07/10/2025 14:53:08

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0

Begin	End
07/10/2025 07/10/2025	
09:32:44 11:42:06	
Result	Pass
Slope	0.02
Status	0
Volume Qualify(%)	14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0

Begin	End
07/10/2025 07/10/2025	
03:26:26 04:53:49	
Result	Pass
Slope	-0.02
Status	0
Volume Qualify(%)	14