

COLFAX EXPRESS
MARATHON
031 E COLFAX
SOUTH BEND
574-232-6727
USA 16:20:09

09/11/2025

TANK TEST REPORT

Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity 6,016.0
Begin 07/22/2020 00:00:55
End 07/22/2020 00:01:04
-----Gross----- 1,696.9
1,696.9
-----Water Level----- 0.02
0.02
-----Water Volume----- 0.0
0.0
-----Net----- 1,686.3
1,686.3
-----Level----- 31.17
31.17
-----Temperature----- 70.07
70.07

Last Delivery
07/18/2020 13:06:30

Test Type Monthly (0.2)

Threshold 0.10

Leak Rate 0.00

Result Aborted

Capacity(%) 28.21

UNLEAD 3
UNLEADED
Capacity 4,011.0
Begin 07/22/2020 00:00:57
End 07/22/2020 03:09:41
-----Gross----- 958.9
958.9
-----Water Level----- 0.03
0.03
-----Water Volume----- 0.1
0.1
-----Net----- 949.1
949.1
-----Level----- 18.46
18.46
-----Temperature----- 74.59
74.59

Last Delivery
07/02/2020 10:49:30

Test Type Monthly (0.2)

Threshold 0.10

Leak Rate -0.11

Result Fail

Capacity(%) 23.83

Details
07/22/2020 03:01:08
Net 946.2
Temperature 74.36
Level 18.42
07/22/2020 02:01:08
Net 946.2
Temperature 74.42
Level 18.42
07/22/2020 01:01:07
Net 946.2
Temperature 74.50
Level 18.42
UNLEAD 1
UNLEADED
Capacity 4,011.0

Begin 07/22/2020 00:01:00
End 07/22/2020 02:59:31
-----Gross----- 688.8
688.8
-----Water Level----- 0.03
0.03
-----Water Volume----- 0.1
0.1
-----Net----- 681.0
681.0
-----Level----- 14.65
14.65
-----Temperature----- 75.93
75.93

Last Delivery
07/02/2020 10:49:30

Test Type Monthly (0.2)

Threshold 0.10

Leak Rate -0.77

Result Fail

Capacity(%) 16.88

Details
07/22/2020 02:01:01
Net 669.4
Temperature 75.80
Level 14.48
07/22/2020 01:01:00
Net 669.4
Temperature 75.89
Level 14.48

Test Type Monthly (0.2)
Threshold 10:49:30
Leak Rate 0.10
Result -0.11
Capacity(%) Fail
23.83

Details
07/22/2020 03:01:08
Net 946.2
Temperature 74.36
Level 18.42

07/22/2020 02:01:08
Net 946.2
Temperature 74.42
Level 18.42

07/22/2020 01:01:07
Net 946.2
Temperature 74.50
Level 18.42

UNLEAD 1
UNLEADED
Capacity 4,011.0

Begin End
07/22/2020 07/22/2020
00:01:00 02:59:31

-----Gross----- 676.9
-----Water Level----- 0.03
-----Water Volume----- 0.1

-----Net----- 669.4
-----Level----- 14.48
-----Temperature----- 75.74

Last Delivery
07/02/2020 10:49:30
Test Type Monthly (0.2)
Threshold 0.10
Leak Rate -0.77
Result Fail
Capacity(%) 16.88

Details
07/22/2020 02:01:01
Net 669.4
Temperature 75.80
Level 14.48

07/22/2020 01:01:00
Net 669.4
Temperature 75.89
Level 14.48

UNLEAD2
UNLEADED
Capacity 4,011.0

Begin End
07/22/2020 07/22/2020
00:00:53 02:49:21

-----Gross----- 554.6
-----Water Level----- 0.03
-----Water Volume----- 0.1

-----Net----- 548.6
-----Level----- 12.63
-----Temperature----- 75.46

Last Delivery
07/02/2020 10:49:30
Test Type Monthly (0.2)
Threshold 0.10
Leak Rate -0.01
Result Pass
Capacity(%) 13.83

Details
07/22/2020 02:01:03
Net 548.6
Temperature 75.50
Level 12.63

07/22/2020 01:01:02
Net 548.6
Temperature 75.57
Level 12.63

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA

09/11/2025 16:20:20
SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Ok
09/11/2025 16:20:20

PREM STP
Alarm
09/11/2025 16:20:20

3 WIRE SENSOR

No Records Found

MAG SENSOR