

COLFAX EXPRESS

MARATHON

831 E COLFAX

SOUTH BEND

574-232-6727

USA

10/12/2025 16:37:35

TANK TEST REPORT

Last Available

Units: gal, in, °F

TANKS

PREMIUM
PREM
Capacity 6,016.0
Begin End
07/22/2020 07/22/2020
00:00:55 00:01:04
-----Gross-----
1,696.9 1,696.9
-----Water Level-----
0.02 0.02
-----Water Volume-----
0.0 0.0
-----Net-----
1,686.3 1,686.3
-----Level-----
31.17 31.17
-----Temperature-----
70.07 70.07

Last Delivery

07/18/2020 13:06:30

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate 0.00

Result Aborted

Capacity(%) 28.21

UNLEAD 3

UNLEADED

Capacity 4,011.0

Begin End
07/22/2020 07/22/2020
00:00:57 03:09:41
-----Gross-----
958.9 955.8
-----Water Level-----
0.03 0.03
-----Water Volume-----
0.1 0.1
-----Net-----
949.1 946.2
-----Level-----
18.46 18.42
-----Temperature-----
74.59 74.35

Last Delivery

07/02/2020 10:49:30

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate -0.11

Result Fail

Capacity(%) 23.83

Details

07/22/2020 03:01:08

Net 946.2

Temperature 74.36

Level 18.42

07/22/2020 02:01:08

Net 946.2

Temperature 74.42

Level 18.42

07/22/2020 01:01:07

Net 946.2

Temperature 74.50

Level 18.42

UNLEAD 1

UNLEADED

Capacity 4,011.0

Begin End
07/22/2020 07/22/2020
00:01:00 02:59:31
-----Gross-----
688.8 676.9
-----Water Level-----
0.03 0.03
-----Water Volume-----
0.1 0.1
-----Net-----
681.0 669.4
-----Level-----
14.65 14.48
-----Temperature-----
75.93 75.74

Last Delivery

07/02/2020 10:49:30

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate -0.77

Result Fail

Capacity(%) 16.88

Details

07/22/2020 02:01:01

Net 669.4

Temperature 75.80

Level 14.48

07/22/2020 01:01:00

Net 669.4

Temperature 75.89

Level 14.48

Capacity 410.1.0
Begin 07/22/2020 00:00:53 End 07/22/2020 02:49:21
-----Gross----- 554.6
555.4
-----Water Level----- 0.03
0.03
-----Water Volume----- 0.1
0.1
-----Net----- 548.6
549.3
-----Level----- 12.63
12.64
-----Temperature----- 75.46
75.62

Last Delivery
07/02/2020 10:49:30
Test Type Monthly (0.2)
Threshold 0.10
Leak Rate -0.01
Result Pass
Capacity(%) 13.83

Details
07/22/2020 02:01:03
Net 548.6
Temperature 75.50
Level 12.63
07/22/2020 01:01:02
Net 548.6
Temperature 75.57
Level 12.63
.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
10/12/2025 16:37:41

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
Ok
10/12/2025 16:37:41

PREM STP
Alarm
10/12/2025 16:37:41

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
10/12/2025 16:37:41

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM
PREM
Capacity: 6,016.0
Begin 10/12/2025 09:02:34 End 10/12/2025 12:14:41
Result Pass
Slope -0.05
Status 0
Volume Qualify(%) 14

MANIFOLDS

Manifold 1
UNLEADED
Capacity: 12,033.0
Begin 09/26/2025 02:46:04 End 09/26/2025 04:13:36
Result Pass
Slope 0.00
Status 0
Volume Qualify(%) 0