

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	15294	Contact Number	
Facility Name	Marathon	Contact email	
Address	831 E Colfax Ave 76617	Date of Inspection	09-11-2025
Operator on Duty Name		Name of the Person Conducting Inspection	burpree

Operator Training current	Operator Training	Operator Notified
☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form	Operator Notified
☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Release Detection Method	Release Detection	☐ SIR ☐ IC ☐ Other
Make and Model	☒ ATG ☐ CIM	
Does it have paper?	☒ Yes ☐ No	Operator Notified
Is it in Alarm mode?	☒ Yes ☐ No	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified
Necessary Monthly Printout Taken	☒ Yes ☐ No	☐ Yes ☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	Spill Buckets	Operator Notified
☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified
☐ Yes ☒ No	Fill Ports	☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☐ Yes ☐ No	Operator Notified
☐ Yes ☐ No	Piping/STP Sumps	☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified
☐ Yes ☐ No	Under Dispenser Containments (UDC)	☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator Notified
☐ Yes ☒ No		☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date

www.tanksdata.com