

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	15299	Contact Number	
Facility Name	MARATHON	Contact email	
Address	831 F Colfax Ave	Date of Inspection	03/19/25
Operator on Duty Name	Scott Bond	Name of the Person Conducting Inspection	ANKIT

Operator Training current	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form		☐ Yes	☐ No	Operator Notified
Release Detection Method	Release Detection		☒ ATG	☐ CIM	☐ SIR
Make and Model	F-55 TS-550				
Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is it in Alarm mode?	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Necessary Monthly Printout Taken	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No

Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com