



5296 Breakers Way, Carmel, IN 46033

Date

2/12/25

PRODUCT LINE TEST

Test Location Information

Name	Colfax Express Marathon
Address	831 E Colfax Ave
City	South Bend, IN, 46617
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:05p	90	0	0.0037	0	0
12:20p	90	0	0.0037	0	0
12:35p	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
12:50p	90	0	0.0037	0	0
1:05pm	90	0	0.0037	0	0
1:20pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 2/12/25

PRODUCT LINE TEST

Test Location Information

Name	Colfax Express Marathon
Address	831 E Colfax Ave
City	South Bend, IN, 46617
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Both ball valves in great working condition. No issues isolating.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 