

00:00:53 02:49:21

COLFAX EXPRESS

MARATHON

831 E COLFAX

SOUTH BEND

574-232-6727

USA

05/12/2025 19:37:00

TANK TEST REPORT

Last Available

units:gal, in, °F

TANKS

PREMIUM

PREM

Capacity 6,016.0

Begin End

07/22/2020 07/22/2020

00:00:55 00:01:04

-----Gross-----

1,696.9 1,696.9

-----Water Level-----

0.02 0.02

-----Water Volume-----

0.0 0.0

-----Net-----

1,686.3 1,686.3

-----level-----

31.17 31.17

-----Temperature-----

70.07 70.07

Last Delivery

07/18/2020 13:06:30

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate 0.00

Result Aborted

Capacity(%) 28.21

UNLEAD 3

UNLEADED

Capacity 4,011.0

Begin End

07/22/2020 07/22/2020

00:00:57 03:09:41

-----Gross-----

958.9 955.8

-----Water Level-----

0.03 0.03

-----Water Volume-----

0.1 0.1

-----Net-----

949.1 946.2

-----Level-----

18.46 18.42

-----Temperature-----

74.59 74.35

Last Delivery

07/02/2020 10:49:30

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate -0.11

Result Fail

Capacity(%) 23.83

Details

07/22/2020 03:01:08

Net 946.2

Temperature 74.36

Level 18.42

07/22/2020 02:01:08

Net 946.2

Temperature 74.42

Level 18.42

07/22/2020 01:01:07

Net 946.2

Temperature 74.50

Level 18.42

UNLEAD 1

UNLEADED

Capacity 4,011.0

Begin End

07/22/2020 07/22/2020

00:01:00 02:59:31

-----Gross-----

688.8 676.9

-----Water Level-----

0.03 0.03

-----Water Volume-----

0.1 0.1

-----Net-----

681.0 669.4

-----Level-----

14.65 14.48

-----Temperature-----

75.93 75.74

Last Delivery

07/02/2020 10:49:30

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate -0.77

Result Fail

Capacity(%) 16.88

Details

07/22/2020 02:01:01

Net 669.4

Temperature 75.80

Level 14.48

07/22/2020 01:01:00

Net 669.4

Temperature 75.89

Level 14.48

UNLEAD2

UNLEADED

Capacity 4,011.0

Begin End

07/22/2020 07/22/2020

00:00:53 02:49:21

-----Gross-----

555.4 554.6

-----Water Level-----

0.03 0.03

-----Water Volume-----

0.1 0.1

-----Net-----

549.3 548.6

-----Level-----

12.64 12.63

-----Temperature-----

75.62 75.46

Last Delivery

07/02/2020 10:49:30

Test Type Monthly(0.2)

Threshold 0.10

Leak Rate -0.01

Result Pass

Capacity(%) 13.83

Details

07/22/2020 02:01:03

Net 548.6

Temperature 75.50

Level 12.63

07/22/2020 01:01:02

Net 548.6

Temperature 75.57

Level 12.63

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
05/12/2025 19:37:02

SCALD REPORT
Last Available

units:gal, in, °F

TANKS

PREMIUM PREM Capacity:	6,016.0
Begin 05/11/2025 15:41:00	End 05/12/2025 03:50:32
Result	Pass
Slope	0.02
Status	0
Volume Qualify(%)	14

MANIFOLDS

Manifold 1 UNLEADED Capacity:	12,033.0
Begin 03/20/2025 11:11:10	End 03/20/2025 12:38:51
Result	Pass
Slope	0.03
Status	0
Volume Qualify(%)	14

.....

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
05/12/2025 19:37:08

SENSOR REPORT
Last Available

2 WIRE SENSOR

UNL STP
OK
05/12/2025 19:37:08

PREM STP
OK
05/12/2025 19:37:08

3 WIRE SENSOR

No Records Found

MAG SENSOR

No Records Found

COLFAX EXPRESS
MARATHON
831 E COLFAX
SOUTH BEND
574-232-6727
USA
05/12/2025 19:37:08

REGULATORY REPORT
(Passed Tests)

units:gph

TANKS (MONTHLY)

Tank 1 PREMIUM SCALD Slope	05-11-2025 15:41:00	0.02
05-12-2025 03:50:32		
05-02-2025 07:43:00		0.03
05-02-2025 09:52:45		
2 WIRE SENSOR (MONTHLY)		
UNL STP	05-12-2025 12:00:00	
PREM STP	05-12-2025 12:00:00	
05-02-2025 12:00:00		