

LSS REAL ESTATE LLC
203 N MAIN ST

NORTH LIBERTY

JUN 6, 2023 12:03 PM

CSLD TEST RESULTS

JUN 6, 2023 12:03 PM

T 1:RNL
T 2:RNL
PROBE SERIAL NUM 473512

C.2 GAL/HR TEST
PER: JUN 6, 2023 PASS

T 3:MID
PROBE SERIAL NUM 570187

C.2 GAL/HR TEST
PER: JUN 6, 2023 PASS

T 4:REM
PROBE SERIAL NUM 139418

C.2 GAL/HR TEST
PER: JUN 6, 2023 PASS

T 5:ERO
PROBE SERIAL NUM 090859

C.2 GAL/HR TEST
PER: JUN 6, 2023 PASS

T 6:DIESEL
PROBE SERIAL NUM 570186

C.2 GAL/HR TEST
PER: JUN 6, 2023 PASS

***** END *****

LSS REAL ESTATE LLC
203 N MAIN ST

NORTH LIBERTY

JUN 6, 2023 12:03 PM

LEAK TEST REPORT

T 1:RNL
PROBE SERIAL NUM 473512

NO TEST DATA AVAILABLE

***** END *****

LSS REAL ESTATE LLC
203 N MAIN ST

NORTH LIBERTY

JUN 6, 2023 12:03 PM

LEAK TEST REPORT

T 2:RNL
PROBE SERIAL NUM 571151

TEST STARTING TIME:
MAR 5, 2012 4:45 PM

HEIGHT = 7.6 INCHES
WATER = 0.8 INCHES
TEMP = 41.8 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 293.5 GAL
PERCENT VOLUME = 3.7

LEAK TEST RESULTS
0.20 GAL/HR TEST IN/L

C.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
INVALID FUEL LEVEL

***** END *****

LSS REAL ESTATE LLC
203 N MAIN ST

NORTH LIBERTY

JUN 6, 2023 12:03 PM

LEAK TEST REPORT

T 3:MID
PROBE SERIAL NUM 570187

TEST STARTING TIME: