

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 15672		Contact Number
Facility Name Phillips 66		Contact email
Address 253 N Main St, NY 14444		Date of Inspection 07/21/2023
Operator on Duty Name DW 46534		Name of the Person Conducting Inspection V. RENDON
Operator Training current		Operator Training
☐ Yes ☐ No		☐ Yes ☐ No
Registration/Notification Form		Registration/Notification Form
☐ Yes ☐ No		☐ Yes ☐ No
Release Detection Method		Release Detection
Make and Model		ATG DIM
Does it have paper?		Yes No
Is it in Alarm mode?		Yes No
Interstitial Monitoring Sensor Status Normal		Operator Notified
Necessary Monthly Printout Taken		Operator Notified
Spill Buckets		Spill Buckets
Are Spill Buckets Clean and free from water, debris, product etc?		Yes No
Are the Spill Bucket in good condition and free of damage/cracks		Yes No
Is Fill pipe cap tight and fill pipe free from any obstruction?		Yes No
Piping/STP Sumps		Piping/STP Sumps
Are Sumps Clean and free from water, debris, product etc?		Yes No
Under Dispenser Containments (UDC)		Under Dispenser Containments (UDC)
Are UDCs clean and free from water, debris, product etc?		Yes No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.		
Operator on Duty Name		Signature
317-645-0215		Date
tanksdata@gmail.com		www.tanksdata.com