



5296 Breakers Way, Carmel, IN 46033

Date

9/18/24

PRODUCT LINE TEST

Test Location Information

Name	FID 15672
Address	203 N Main St
City	North Liberty, IN, 46554
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:40p	90	0	0.0037	0	0
12:55p	90	0	0.0037	0	0
1:10pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:25pm	84	0	0.0037	0	0
1:40pm	83	-1	0.0037	.0037	.0148
1:55pm	83	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
2:50pm	90	0	0.0037	0	0
3:05pm	90	0	0.0037	0	0
3:20pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#4 Product Type : Mid-grade

TIME	DATA	+/-	GPL	RES	GPH
2:10pm	86	0	0.0037	0	0
2:25pm	86	0	0.0037	0	0
2:40pm	86	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					



5296 Breakers Way, Carmel, IN 46033

Date 9/18/24

PRODUCT LINE TEST

Test Location Information

Name	FID 15672
Address	203 N Main St
City	North Liberty, IN, 46554
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4	Mid-grade	Pass
5		
6		

Comment :

Tester's Name : Josh Rider

Tester's Signature : 