

NORTH LIBERTY
NOV 8. 2024 4:41 PM
CSLD TEST RESULTS

NOV 8. 2024 4:41 PM

T 1:3NL
T 2:3NL
PROBE SERIAL NUM 473512
C.2 GAL/HR TEST
PER: NOV 8. 2024 PASS

T 3:MID
PROBE SERIAL NUM 570187
C.2 GAL/HR TEST
PER: NOV 8. 2024 PASS

T 4:PREM
PROBE SERIAL NUM 109418
C.2 GAL/HR TEST
PER: NOV 8. 2024 PASS

T 5:XERO
PROBE SERIAL NUM 090859
C.2 GAL/HR TEST
PER: NOV 8. 2024 PASS

T 6:DIESEL
PROBE SERIAL NUM 570186
C.2 GAL/HR TEST
PER: NOV 8. 2024 PASS

* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY
NOV 8. 2024 4:41 PM
LEAK TEST REPORT
T 1:3NL
PROBE SERIAL NUM 473512
NO TEST DATA AVAILABLE
* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY
NOV 8. 2024 4:41 PM
LEAK TEST REPORT
T 2:3NL
PROBE SERIAL NUM 571151
TEST STARTING TIME:
MAR 5. 2012 4:45 PM
HEIGHT = 7.6 INCHES
WATER = 0.8 INCHES
TEMP = 41.8 F
TEST LENGTH = 3.0 HRS
STRT VOLUME = 293.5 GAL
PERCENT VOLUME = 3.7
LEAK TEST RESULTS
0.20 GAL/HR TEST INVL
C.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
INVALID FUEL LEVEL
* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY
NOV 8. 2024 4:41 PM
LEAK TEST REPORT
T 3:MID
PROBE SERIAL NUM 570187
TEST STARTING TIME:
JAN 18. 2012 11:00 PM

HEIGHT = 16.7 INCHES
WATER = 1.1 INCHES
TEMP = 48.0 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 709.0 GAL
PERCENT VOLUME = 11.8

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

C.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY

NOV 8, 2024 4:41 PM

LEAK TEST REPORT

T 4:2REM
PROBE SERIAL NUM 139418

TEST STARTING TIME:
JAN 18, 2012 11:00 PM

HEIGHT = 29.9 INCHES
WATER = 0.0 INCHES
TEMP = 46.5 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 1861.6 GAL
PERCENT VOLUME = 46.3

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY

NOV 8, 2024 4:41 PM

LEAK TEST REPORT

T 5:KERO
PROBE SERIAL NUM 090859

TEST STARTING TIME:
JAN 18, 2012 11:00 PM

HEIGHT = 17.6 INCHES
WATER = 1.3 INCHES
TEMP = 46.9 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 448.1 GAL
PERCENT VOLUME = 22.4

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

C.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY

NOV 8, 2024 4:41 PM

LEAK TEST REPORT

T 6:DIESEL
PROBE SERIAL NUM 570186

TEST STARTING TIME:
NOV 21, 2013 9:02 AM

HEIGHT = 23.6 INCHES
WATER = 0.9 INCHES
TEMP = 57.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1150.9 GAL
PERCENT VOLUME = 19.1

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL