

LSS REAL ESTATE LLC
203 N MAIN ST

NORTH LIBERTY

DEC 23, 2024 6:39 PM

CSLD TEST RESULTS

DEC 23, 2024 6:39 PM

T 1:RNL

T 2:RNL

PROBE SERIAL NUM 473512

0.2 GAL/HR TEST

PER: DEC 23, 2024 PASS

T 3:MID

PROBE SERIAL NUM 570187

0.2 GAL/HR TEST

PER: DEC 23, 2024 PASS

T 4:PREM

PROBE SERIAL NUM 139418

0.2 GAL/HR TEST

PER: DEC 23, 2024 PASS

T 5:KERO

PROBE SERIAL NUM 090859

0.2 GAL/HR TEST

PER: DEC 23, 2024 PASS

T 6:DIESEL

PROBE SERIAL NUM 570186

0.2 GAL/HR TEST

PER: DEC 23, 2024 PASS

***** END *****

LSS REAL ESTATE LLC

203 N MAIN ST

NORTH LIBERTY

DEC 23, 2024 6:39 PM

LEAK TEST REPORT

T 1:RNL

PROBE SERIAL NUM 473512

NO TEST DATA AVAILABLE

***** END *****

LSS REAL ESTATE LLC

203 N MAIN ST

NORTH LIBERTY

DEC 23, 2024 6:39 PM

LEAK TEST REPORT

T 2:RNL

PROBE SERIAL NUM 571151

TEST STARTING TIME:

MAR 5, 2012 4:45 PM

HEIGHT = 7.6 INCHES

WATER = 0.8 INCHES

TEMP = 41.8 F

TEST LENGTH = 3.0 HRS

STRT VOLUME = 293.5 GAL

PERCENT VOLUME = 3.7

LEAK TEST RESULTS

0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:

LOW LEVEL TEST ERROR

INVALID FUEL LEVEL

***** END *****

LSS REAL ESTATE LLC

203 N MAIN ST

NORTH LIBERTY

DEC 23, 2024 6:39 PM

LEAK TEST REPORT

T 3:MID

PROBE SERIAL NUM 570187

TEST STARTING TIME:
JAN 18, 2012 11:00 PM
HEIGHT = 16.7 INCHES
WATER = 1.1 INCHES
TEMP = 48.0 F
TEST LENGTH = 3.0 HRS
STRT VOLUME = 709.0 GAL
PERCENT VOLUME = 11.8
LEAK TEST RESULTS
0.20 GAL/HR TEST INVL
0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY
DEC 23, 2024 6:39 PM
LEAK TEST REPORT
T 4:PREM
PROBE SERIAL NUM 139418
TEST STARTING TIME:
JAN 18, 2012 11:00 PM
HEIGHT = 29.9 INCHES
WATER = 0.0 INCHES
TEMP = 46.5 F
TEST LENGTH = 3.0 HRS
STRT VOLUME = 1861.6 GAL
PERCENT VOLUME = 46.3
LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS
* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY
DEC 23, 2024 6:39 PM
LEAK TEST REPORT
T 5:KERO
PROBE SERIAL NUM 090859
TEST STARTING TIME:
JAN 18, 2012 11:00 PM
HEIGHT = 17.6 INCHES
WATER = 1.3 INCHES
TEMP = 46.9 F
TEST LENGTH = 3.0 HRS
STRT VOLUME = 448.1 GAL
PERCENT VOLUME = 22.4
LEAK TEST RESULTS
0.20 GAL/HR TEST INVL
0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
* * * * * END * * * * *

LSS REAL ESTATE LLC
203 N MAIN ST
NORTH LIBERTY
DEC 23, 2024 6:39 PM
LEAK TEST REPORT
T 6:DIESEL
PROBE SERIAL NUM 570186
TEST STARTING TIME:
NOV 21, 2013 9:02 AM
HEIGHT = 23.6 INCHES
WATER = 0.9 INCHES
TEMP = 57.1 F
TEST LENGTH = 2.0 HRS
STRT VOLUME = 1150.9 GAL
PERCENT VOLUME = 19.1
LEAK TEST RESULTS
0.20 GAL/HR TEST INVL
0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
* * * * * END * * * * *