



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

10/14/25

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 15672
Address	203 N Main St
City	North Liberty, IN, 46554
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		
Dies	Fe Petro MLLD		
Mid	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	30	30	130 ml	189ml	3 sec	Pass 
2	Premium	37	35	120 ml	189ml	2 sec	Pass 
3	Diesel	31	29	80 ml	189ml	2 sec	Pass 
4	Mid-grade	30	26	160 ml	189ml	3 sec	Pass 
5					189ml		. 
6					189ml		. 
7					189ml		. 
8					189ml		. 

Comment:

Technician Signature :

