

001
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2255		Contact Number
Facility Name Shell		Contact email
Address 1401 E 29th Avenue, 47302		Date of Inspection 08/16/24
Operator on Duty Name		Name of the Person Conducting Inspection AKMUT

Operator Training current	Operator Training	Registration/Notification Form	Release Detection
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	☐ Yes ☐ No	☒ ATG ☐ CIM ☐ SIR
Release Detection Method			
Make and Model			
Does it have paper?	☒ Yes ☐ No		☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No		☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No		☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No		☐ Yes ☐ No

Spill Buckets	Operator Notified	Operator Notified
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	☒ Yes ☐ No

Fill Ports	Operator Notified	Operator Notified
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	☒ Yes ☐ No

Pipeline/STP Sumps	Operator Notified	Operator Notified
Are Sumps Clean and free from water, debris, product etc?	☒ Yes ☐ No	☒ Yes ☐ No

Under Dispenser Containments (UDC)	Operator Notified	Operator Notified
Are UDCs clean and free from water, debris, product etc?	☒ Yes ☐ No	☒ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com