

001

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2255		Contact Number
Facility Name Shell		Contact email
Address 1401 E 29th, Meriden, CT		Date of Inspection 12/12/24
Operator on Duty Name 47302		Name of the Person Conducting Inspection
Operator Training		Operator Training
Operator Training current ☐ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Is Registration current with correct owner, operator etc. ☐ Yes ☐ No		Registration/Notification Form ☐ Yes ☐ No
Release Detection Method		Release Detection
Make and Model ☒ ATG ☐ DIM		☒ ATG ☐ DIM
Does it have paper? ☒ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Is it in Alarm mode? ☒ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal		Operator Notified ☐ Yes ☐ No
Necessary Monthly Printout Taken ☒ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Spill Buckets		Spill Buckets
Are Spill Buckets Clean and free from water, debris, product etc? ☒ Yes ☐ No		Operator Notified ☒ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks ☒ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction? ☒ Yes ☐ No		Operator Notified ☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc? ☒ Yes ☐ No		Operator Notified ☒ Yes ☐ No
Under Dispenser Containments (UDC) ☒ Yes ☐ No		Operator Notified ☒ Yes ☐ No
Are UDCs clean and free from water, debris, product etc? ☒ Yes ☐ No		Operator Notified ☒ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.		
Operator on Duty Name		Signature
317-645-0215		Date
tanksdata@gmail.com		www.tanksdata.com