

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) #	2255	Contact Number	
Facility Name	Shell	Contact email	
Address	1401 E 29th Avenue	Date of Inspection	12/18/21
Operator on Duty Name	Y 7302	Name of the Person Conducting Inspection	AKSMT

Operator Training current

Operator Training

☐ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

☐ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Release Detection Method

Release Detection

☒ ATG

☐ GIM

☐ SIR

☐ IC

☐ Other

Make and Model

Does it have paper?

Is it in Alarm mode?

Interstitial Monitoring Sensor Status Normal

Necessary Monthly Printout Taken

Spill Buckets

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Piping/STP Sumps

☐ Yes

☒ No

Operator Notified

☒ Yes

☐ No

Are Sumps Clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)

☒ Yes

☐ No

Operator Notified

☐ Yes

☐ No

Are UDCs clean and free from water, debris, product etc?

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

tanksdata@gmail.com

Signature

Date

www.tanksdata.com