

001
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (RID) #	2255	Contact Number	
Facility Name	Shell	Contact email	
Address	1401 E 28th Avenue, NW 17302	Date of Inspection	07/18/24
Operator on Duty Name		Name of the Person Conducting Inspection	AKSHIT SHARMA

Operator Training		Registration/Notification Form	
Operator Training current	☐ Yes ☐ No	Is Registration current with correct owner, operator etc.	☐ Yes ☐ No
Release Detection Method		Release Detection	
Make and Model	EMC 6116-112	MTG	IC
Does it have paper?	☒ Yes ☐ No	Operator/Notified	☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes ☒ No	Operator/Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator/Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☐ Yes ☒ No	Operator/Notified	☐ Yes ☐ No

Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator/Notified	☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☐ Yes ☒ No	Operator/Notified	☐ Yes ☐ No

Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	☐ Yes ☒ No	Operator/Notified	☐ Yes ☐ No

Piping/STP Sumps			
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator/Notified	☐ Yes ☐ No

Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	Operator/Notified	☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com