



ACCURITE SYSTEMS PRODUCT LINE TESTER DATA SHEET



TEST DATE: 8/15/2024
LOCATION NAME: Muncie Southside Shell
LOCATION ADDRESS: 1401 E 29th Street
LOCATION CITY/STATE: Muncie, IN 47302
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Virendar Kumar

OWNER NAME: TriStar Holding, Inc
OWNER ADDRESS: Muncie Southside Shell
OWNER CITY/STATE/ZIP: 1401 E 29th Street

LOCATION FID#: 02255
WORK ORDER NO: NE-1252

TANK #					
1&2	PRODUCT TYPE:	RUL			
	OPERATING SYSTEM:	PRESSURE			
	STP MODEL:	RJ			
	OPERATING PRESSURE:	30			
	TEST PRESSURE:	50			
	ISOLATION:	CK VLV			
	LINE MATERIAL:	FG			
TIME	DATA				
BEG LVL	0.089				
10 MIN	0.0885				
20 MIN	0.0885				
30 MIN	0.0885				
FINAL RESULT		PASS	AMT OF CHG	0.001	

TANK #					
3	PRODUCT TYPE:	PUL			
	OPERATING SYSTEM:	PRESSURE			
	STP MODEL:	RJ			
	OPERATING PRESSURE:	30			
	TEST PRESSURE:	50			
	ISOLATION:	CK VLV			
	LINE MATERIAL:	FG			
TIME	DATA				
BEG LVL	0.089				
10 MIN	0.0885				
20 MIN	0.0885				
30 MIN	0.0885				
FINAL RESULT		PASS	AMT OF CHG	0.001	

TANK #					
4	PRODUCT TYPE:	DSL			
	OPERATING SYSTEM:	PRESSURE			
	STP MODEL:	RJ			
	OPERATING PRESSURE:	30			
	TEST PRESSURE:	50			
	ISOLATION:	CK VLV			
	LINE MATERIAL:	FG			
TIME	DATA				
BEG LVL	0.0495				
10 MIN	0.0475				
20 MIN	0.0475				
30 MIN	0.0475				
FINAL RESULT		PASS	AMT OF CHG	0.002	

TANK #					
5	PRODUCT TYPE:	TRUCK DSL			
	OPERATING SYSTEM:	PRESSURE			
	STP MODEL:	RJ			
	OPERATING PRESSURE:	30			
	TEST PRESSURE:	50			
	ISOLATION:	BV			
	LINE MATERIAL:	FG			
TIME	DATA				
BEG LVL	0.075				
10 MIN	0.0745				
20 MIN	0.0745				
30 MIN	0.0745				
FINAL RESULT		PASS	AMT OF CHG	0.001	

TANK #					
	PRODUCT TYPE:				
	OPERATING SYSTEM:				
	STP MODEL:				
	OPERATING PRESSURE:				
	TEST PRESSURE:				
	ISOLATION:				
	LINE MATERIAL:				
TIME	DATA				
BEG LVL					
10 MIN					
20 MIN					
30 MIN					
FINAL RESULT		-	AMT OF CHG		

TANK #					
	PRODUCT TYPE:				
	OPERATING SYSTEM:				
	STP MODEL:				
	OPERATING PRESSURE:				
	TEST PRESSURE:				
	ISOLATION:				
	LINE MATERIAL:				
TIME	DATA				
BEG LVL					
10 MIN					
20 MIN					
30 MIN					
FINAL RESULT		-	AMT OF CHG		

RONNIE BROWN
CERTIFIED TECHNICIAN NAME (printed)

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC112255
EXPIRATION DATE: 01/23/2025