

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2255

Facility Name Shell

Address 161 E 29th St

Operator on Duty Name

Contact Number

Contact email

Date of Inspection 3-18-29

Name of the Person Conducting Inspection Austin B

Operator Training current

Operator Training

Operator/Notified

Is Registration current with correct owner, operator etc.

Registration/Notification Form

Operator/Notified

Release Detection Method

Release Detection

Operator/Notified

Make and Model

ATG

BIR

Does it have paper?

5:16wca 2m c

Operator/Notified

Is it in Alarm mode?

Yes

Operator/Notified

Are Spill Buckets Clean and free from water, debris, product etc?

Spill Buckets

Operator/Notified

Are the Spill Bucket in good condition and free of damage/cracks

Yes

Operator/Notified

Is Fill pipe cap tight and fill pipe free from any obstruction?

Fill Ports

Operator/Notified

Are Sumps Clean and free from water, debris, product etc?

Piping/STP Sumps

Operator/Notified

Are UDCs clean and free from water, debris, product etc?

Under Dispenser Containments (UDC)

Operator/Notified

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com