

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	2255	Contact Number	
Facility Name	Shell	Contact email	
Address	1401 E. 29th St	Date of Inspection	03/30/25
Operator on Duty Name	Marice J. - 47302	Name of the Person Conducting Inspection	Amk, Y

Operator Training current	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No		
Is Registration current with correct owner, operator etc.	Registration/Notification Form		☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No
Release Detection Method	Release Detection		☒ ATG	☐ CIM	☐ SIR	☐ IC	☐ Other
Make and Model			2M1614BAG				
Does it have paper?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Is it in Alarm mode?	☐ Yes	☒ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Necessary Monthly Printout Taken	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Spill Buckets	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Piping/STP Sumps	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	☐ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name _____ Signature _____ Date _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com