

FEB 29
1: UNLEADED 1
PROBE SERIAL NUM 137096
0.2 GAL/HR TEST
PER: FEB 29, 2024 PPSB
2
NUM 26C531

0.2
PER: FEB
3: PREMIUM
PROBE SERIAL NUM 217696
0.2 GAL/HR TEST
PER: FEB 29. 2024 PASS
NUM 245872

HOOSIER PETE
9500 ST RD 3
RCYERTON IN 47303
765 286 1849
FEB 29, 2024 3:19 PM
LEAK TEST REPORT
PAGE 1 OF 1

TEST LENGTH = 24.0 HRS
SIRT VOLUME = 3184.4 GAL

START TEMP = 45.0 F
END TEMP = 43.7 F

LEAK TEST RESULTS
RATE = 130.29 GAL/HR
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
RECENT DELIVERY
PRODUCT LEVEL INCREASE

TEST STARTING TIME:
FEB 15, 2024 8:08 AM

```
TEST LENGTH = 24.0 HRS
SIRT VOLUME = 4842.4 GAL

START TEMP = 45.5 F
END TEMP = 44.8 F
```