

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 2256		Contact Number
Facility Name Shell		Contact email
Address 7910 North State Road 3, Mound		Date of Inspection 07/18/27
Operator on Duty Name LA 17303		Name of the Person Conducting Inspection AKSHIT SAMPAT
Operator Training		
Operator Training current	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Is Registration current with correct owner, operator etc.	Registration/Notification Form ☐ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Release Detection Method	Release Detection ☒ ATG ☐ CDM ☐ SIR ☐ OC ☐ Other	
Make and Model	1/R TLS 350	
Does it have paper?	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Spill Buckets		
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	Fill Ports ☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Are Sumps Clean and free from water, debris, product etc?	Piping/STP Sumps ☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
Are UDCs clean and free from water, debris, product etc?	Under Dispenser Containments (UDC) ☒ Yes ☐ No	Operator Notified ☐ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.		
Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com